

[Provisional Translation Only]

This English translation of the original Japanese document is provided solely for information purposes. Should there be any discrepancies between this translation and the Japanese original, the latter shall prevail.

April 3, 2015

## Ichigo Group Holdings Co., Ltd. (JASDAQ, 2337)

Representative: Scott Callon, Chairman and Representative Statutory Executive Officer

Inquiries: Takeyuki Yoshimatsu, Senior Statutory Executive Officer Telephone: +81-3-3502-4818 <u>www.ichigo-holdings.co.jp/english</u>

## Ichigo Solar Power Generation and CO2 Reduction Data – March 2015

FY February 2015		
	Power Generation (kWh)	CO <sup>2</sup> Reduction (kg-CO <sup>2</sup> ) <sup>1</sup>
March	963,170	635,692
April	1,445,602	954,097
May	1,611,799	1,063,787
June	1,367,750	902,714
July	1,466,574	967,939
August	1,175,943	776,122
H1	8,030,839	5,300,353
September	1,276,316	842,368
October	1,245,766	822,206
November	1,141,725	753,538
December	1,140,094	752,462
January	1,254,499	827,969
February	2,382,451	1,572,417
H2	8,440,854	5,570,963
Full Year	16,471,694	10,871,317

FY February 2016		
	Power Generation (kWh)	CO <sup>2</sup> Reduction (kg-CO <sup>2</sup> ) <sup>1</sup>
March	3,203,083	2,114,035
April		
May		
June		
July		
August		
H1		
September		
October		
November		
December		
January		
February		
H2		
Full Year		

## **Explanation**

Power generation in March was 3,203,083 kWh, falling short of the P50<sup>2</sup> power production forecast of 3,308,000 kWh. While record-breaking snowfalls lowered power generation in Hokkaido to 15% below the P50 forecast, power generation outside Hokkaido exceeded the forecast by 7%. Total power generation was thus just 3% below forecast, underscoring the strength of Ichigo's diversified power plant portfolio. The P50 forecast for April is 3,396,000 kWh.

Detailed production data for each Ichigo solar power plant is available on the website of Ichigo ECO Energy: <a href="https://www.ichigo-holdings.co.jp/eco/english/">www.ichigo-holdings.co.jp/eco/english/</a>

<sup>&</sup>lt;sup>1</sup>CO<sup>2</sup> reduction is calculated as 0.66kg CO<sup>2</sup> per kWh.

<sup>&</sup>lt;sup>2</sup> P50 is a third-party, 50% probability mean annual production forecast that serves as the base forecast for each solar power plant's operating plan.