

Creating peace of mind through honest and committed management.



September 3, 2015

Year-on-

Year

Change

+232.6%

+140.3%

+155.7%

+167.8%

+178.5%+224.2%

+178.4%

[Provisional Translation Only]

This English translation of the original Japanese document is provided solely for information purposes. Should there be any discrepancies between this translation and the Japanese original, the latter shall prevail.

Ichigo Inc. (JASDAQ, 2337)

Representative: Scott Callon, Chairman and Representative Statutory Executive Officer Inquiries: Takeyuki Yoshimatsu, Senior Statutory Executive Officer Telephone: +81-3-3502-4818 www.ichigo.gr.jp/english

## Ichigo Solar Power Generation and CO<sup>2</sup> Reduction Data – August 2015

FY15/2		
	Power Generation (kWh)	$CO^{2}$ Reduction $(kg-CO^{2})^{1}$
March	963,170	635,692
April	1,445,602	954,097
May	1,611,799	1,063,787
June	1,367,750	902,714
July	1,466,574	967,939
August	1,175,943	776,122
H1	8,030,839	5,300,353
September	1,276,316	842,368
October	1,245,766	822,206
November	1,141,725	753,538
December	1,140,094	752,462
January	1,254,499	827,969
February	2,382,451	1,572,417
H2	8,440,854	5,570,963
Full Year	16,471,694	10,871,317

## **Explanation**

Power generation in August was 3,812,172 kWh. This was 4% lower than the forecast  $P50^2$  power production of 3,988,000 kWh due to negative weather conditions but a 3.2X increase year-on-year. Power generation for the full first-half (H1) was 3% above forecast. The P50 forecast for September is 3,574,000 kWh.

 $^{1}$ CO<sup>2</sup> reduction is calculated as 0.66kg CO<sup>2</sup> per kWh.

<sup>2</sup> P50 is a third-party, 50% probability mean annual production forecast that serves as the base forecast for each solar power plant's operating plan.

Detailed production data for each Ichigo solar power plant is available on the website of Ichigo ECO Energy: <u>www.ichigo.gr.jp/eco/english/</u>