

## Creating peace of mind through honest and committed management.



[Provisional Translation Only]

This English translation of the original Japanese document is provided solely for information purposes. Should there be any discrepancies between this translation and the Japanese original, the latter shall prevail.

December 3, 2015

**Ichigo Inc.** (Tokyo Stock Exchange First Section, 2337)

Representative: Scott Callon, Chairman & Representative Statutory Executive Officer

Inquiries: Takeyuki Yoshimatsu, Senior Statutory Executive Officer

Telephone: +81-3-3502-4818 www.ichigo.gr.jp/english

## Ichigo Solar Power Generation and CO<sup>2</sup> Reduction Data – November 2015

FY15/2				
	Power Generation (kWh)	CO <sup>2</sup> Reduction (kg-CO <sup>2</sup> ) <sup>1</sup>		
March	963,170	635,692		
April	1,445,602	954,097		
May	1,611,799	1,063,787		
June	1,367,750	902,714		
July	1,466,574	967,939		
August	1,175,943	776,122		
H1	8,030,839	5,300,353		
September	1,276,316	842,368		
October	1,245,766	822,206		
November	1,141,725	753,538		
December	1,140,094	752,462		
January	1,254,499	827,969		
February	2,382,451	1,572,417		
H2	8,440,854	5,570,963		
Full Year	16,471,694	10,871,317		

FY16/2				
	Power Generation (kWh)	CO <sup>2</sup> Reduction (kg-CO <sup>2</sup> ) <sup>1</sup>	Year-on- Year Change	
March	3,203,083	2,114,035	+232.6%	
April	3,474,152	2,292,940	+140.3%	
May	4,122,044	2,720,549	+155.7%	
June	3,663,109	2,417,652	+167.8%	
July	4,083,889	2,695,367	+178.5%	
August	3,812,172	2,516,033	+224.2%	
H1	22,358,452	14,756,578	+178.4%	
September	3,658,084	2,414,335	+186.6%	
October	4,111,990	2,713,913	+230.1%	
November	2,501,232	1,650,813	+119.0%	
December	_			
January				
February				
H2	_	_	_	
Full Year	_	_	_	

## **Explanation**

Power generation in November was 2,501,232 kWh, a 2.2X increase year-on-year, but fell 6% below the P50<sup>2</sup> power production forecast of 2,654,000 kWh due to the lowest total productive daylight hours in eastern Japan for November since 1946. The P50 forecast for December is 2,556,000 kWh, with the Ichigo Yamaguchi Aionishi ECO Power Plant and Ichigo Hamanaka Bokujo Tsurunokotai ECO Power Plant beginning operation this month.

Detailed production data for each Ichigo solar power plant is available on the website of Ichigo ECO Energy: www.ichigo.gr.jp/eco/english/

<sup>&</sup>lt;sup>1</sup>CO<sup>2</sup> reduction is calculated as 0.66kg CO<sup>2</sup> per kWh.

<sup>&</sup>lt;sup>2</sup> P50 is a third-party, 50% probability mean annual production forecast that serves as the base forecast for each solar power plant's operating plan.